



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
 11101
 Phone (718) 937-3720 Fax (718) 937-3721
 AIRTEKENV.COM

Date: 1/15/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
 ADDRESS: 500 Kent Avenue
Brooklyn, NY
 ROTOMETER No 1
 CALIBRATION DATE: 12/31/2013
 EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille
 AIRTEK PROJECT #: 13-1013
 MATERIAL: Soil Excavation
 AMOUNT: _____
 TIME ON: 07:12 TIME OFF: 15:32
 TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM ² *
011514-975	Inside Work Area Next to the Electrical Box Upwind B-1	7:09	15:09	3.016	3.016	<17.56
011514-976	Outside Work Area Personal Decon C-3	7:10	15:10	3.016	3.016	<17.56
011514-977	Outside Work Area Waste Decon Area Downwind C-3	7:12	15:12	3.016	3.016	<17.56
011514-978	Outside Work Area 2ft from Security Box Upwind B-1	7:14	15:15	3.016	3.016	<17.56
011514-979	Outside Work Area 4ft from Security Box Upwind B-1	7:17	15:17	3.016	3.016	<17.56
011514-980	Outside Work Area Right of Yard Upwind B-2	7:19	15:19	3.016	3.016	<17.56
011514-981	Outside Work Area Center of Yard Upwind B-2	7:22	15:23	3.016	3.016	<17.56
011514-982	Outside Work Area Left of Yard Downwind B-3	7:24	15:25	3.016	3.016	<17.56
011514-983	Outside Work Area Left of South/West Side Downwind B-4	7:26	15:26	3.016	3.016	<17.56
011514-984	Outside Work Area Center of South/West Side Downwind B-4	7:28	15:28	3.016	3.016	<17.56
011514-985	Outside Work Area Right of South/West Side Downwind A-4	7:30	15:30	3.016	3.016	<17.56

FIELD NOTES:
 *STRUCTURES /PER MM² - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City 11101
Phone (718) 937-3720 Fax (718) 937-3721
AIRTEKENV.COM

Date: 1/14/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/31/2013
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:12 TIME OFF: 15:32
TOTAL # OF SAMPLES 11

Table with columns: SAMPLE #, WORK AREA, START TIME, END TIME, INITIAL FLOW, FINAL FLOW, STRUCTURE S/PER MM2*. Contains 11 rows of sampling data.

FIELD NOTES:
*STRUCTURES /PER MM2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
 11101
 Phone (718) 937-3720 Fax (718) 937-3721
 AIRTEKENV.COM

Date: 1/13/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
 ADDRESS: 500 Kent Avenue
Brooklyn, NY
 ROTOMETER No: 1
 CALIBRATION DATE: 12/31/2013
 EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille
 AIRTEK PROJECT #: 13-1013
 MATERIAL: Soil Excavation
 AMOUNT: _____
 TIME ON: 07:10 TIME OFF: 15:31
 TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURES /PER MM ²⁺
011314-933	Inside Work Area Next to the Electrical Box Upwind B-1	7:10	15:11	3.06	3.06	<17.56
011314-934	Outside Work Area Personal Decon C-3	7:12	15:12	3.06	3.06	<17.56
011314-935	Outside Work Area Waste Decon Area Downwind C-3	7:14	15:14	3.06	3.06	<17.56
011314-936	Outside Work Area 2ft from Security Box Upwind B-1	7:17	15:18	3.06	3.06	<17.56
011314-937	Outside Work Area 4ft from Security Box Upwind B-1	7:19	15:20	3.06	3.06	<17.56
011314-938	Outside Work Area Right of Yard Upwind B-2	7:22	15:23	3.06	3.06	<17.56
011314-939	Outside Work Area Center of Yard Upwind B-2	7:24	15:24	3.06	3.06	<17.56
011314-940	Outside Work Area Left of Yard Downwind B-3	7:26	15:26	3.06	3.06	<17.56
011314-941	Outside Work Area Left of South/West Side Downwind B-4	7:28	15:28	3.06	3.06	<17.56
011314-942	Outside Work Area Center of South/West Side Downwind B-4	7:30	15:30	3.06	3.06	<17.56
011314-943	Outside Work Area Right of South/West Side Downwind A-4	7:31	15:31	3.06	3.06	<17.56

FIELD NOTES:
 *STRUCTURES /PER MM² - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
 11101
 Phone (718) 937-3720 Fax (718) 937-3721
 AIRTEKENV.COM

Date: 1/10/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: <u>500 Kent Avenue</u>	PROJECT MONITOR: <u>Gary Credille</u>
ADDRESS: <u>500 Kent Avenue</u>	AIRTEK PROJECT #: <u>13-1013</u>
	MATERIAL: <u>Soil Excavation</u>
ROTOMETER No: <u>omega HF-10</u>	AMOUNT: _____
CALIBRATION DATE: <u>12/17/2013</u>	TIME ON: <u>07:00</u> TIME OFF: <u>15:30</u>
EXPIRATION DATE: <u>3/17/2014</u>	TOTAL # OF SAMPLES <u>11</u>

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM ² *
011014-912	Inside Work Area Next to the Electrical Box Downwind B-1	7:08	15:09	3.46	3.46	<17.56
011014-913	Outside Work Area Personal Decon C-3	7:11	15:11	3.46	3.46	<17.56
011014-914	Outside Work Area Waste Decon Area Upwind C-3	7:13	15:14	3.46	3.46	<17.56
011014-915	Outside Work Area 2ft from Security Box Downwind B-1	7:15	15:16	3.46	3.46	<17.56
011014-916	Outside Work Area 4ft from Security Box Downwind B-1	7:16	15:17	3.46	3.46	<17.56
011014-917	Outside Work Area Right of Yard Downwind B-2	7:20	15:20	3.46	3.46	<17.56
011014-918	Outside Work Area Center of Yard Downwind B-2	7:21	15:21	3.46	3.46	<17.56
011014-919	Outside Work Area Left of Yard Upwind B-3	7:23	15:23	3.46	3.46	<17.56
011014-920	Outside Work Area Left of South/West Side Upwind B-4	7:25	15:26	3.46	3.46	<17.56
011014-921	Outside Work Area Center of South/West Side Upwind B-4	7:27	15:28	3.46	3.46	<17.56
011014-922	Outside Work Area Right of South/West Side Upwind A-4	7:29	15:29	3.46	3.46	<17.56

FIELD NOTES:
 *STRUCTURES /PER MM² - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-3721
AIRTEKENV.COM

Date: 1/9/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No omega HF-10
CALIBRATION DATE: 12/17/2013
EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT: _____
TIME ON: 07:00 TIME OFF: 15:30
TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM ² *
010914-891	Inside Work Area Next to the Electrical Box Downwind B-1	7:09	15:09	3.46	3.46	<17.56
010914-892	Outside Work Area Personal Decon C-3	7:10	15:10	3.46	3.46	<17.56
010914-893	Outside Work Area Waste Decon Area Upwind C-3	7:12	15:12	3.46	3.46	<17.56
010914-894	Outside Work Area 2ft from Security Box Downwind B-1	7:14	15:15	3.46	3.46	<17.56
010914-895	Outside Work Area 4ft from Security Box Downwind B-1	7:17	15:18	3.46	3.46	<17.56
010914-896	Outside Work Area Right of Yard Downwind B-2	7:19	15:20	3.46	3.46	<17.56
010914-897	Outside Work Area Center of Yard Downwind B-2	7:22	15:23	3.46	3.46	<17.56
010914-898	Outside Work Area Left of Yard Upwind B-3	7:24	15:24	3.46	3.46	<17.56
010914-899	Outside Work Area Left of South/West Side Upwind B-4	7:26	15:26	3.46	3.46	<17.56
010914-900	Outside Work Area Center of South/West Side Upwind B-4	7:28	15:28	3.46	3.46	<17.56
010914-901	Outside Work Area Right of South/West Side Upwind A-4	7:30	15:30	3.46	3.46	<17.56

FIELD NOTES:

*STRUCTURES /PER MM² - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-
3721
AIRTEKENV.COM

Date: 1/8/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No omega HF-10
CALIBRATION DATE: 12/17/2013
EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT: _____
TIME ON: 07:00 TIME OFF: 15:30
TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM ² *
010814-870	Inside Work Area Next to the Electrical Box Downwind B-1	7:08	15:09	3.46	3.46	<17.56
010814-871	Outside Work Area Personal Decon C-3	7:11	15:12	3.46	3.46	<17.56
010814-872	Outside Work Area Waste Decon Area Upwind C-3	7:13	15:13	3.46	3.46	<17.56
010814-873	Outside Work Area 2ft from Security Box Downwind B-1	7:15	15:15	3.46	3.46	<17.56
010814-874	Outside Work Area 4ft from Security Box Downwind B-1	7:16	15:16	3.46	3.46	<17.56
010814-875	Outside Work Area Right of Yard Downwind B-2	7:18	15:18	3.46	3.46	<17.56
010814-876	Outside Work Area Center of Yard Downwind B-2	7:20	15:21	3.46	3.46	<17.56
010814-877	Outside Work Area Left of Yard Upwind B-3	7:21	15:22	3.46	3.46	<17.56
010814-878	Outside Work Area Left of South/West Side Upwind B-4	7:23	15:23	3.46	3.46	<17.56
010814-879	Outside Work Area Center of South/West Side Upwind B-4	7:25	15:25	3.46	3.46	<17.56
010814-880	Outside Work Area Right of South/West Side Upwind A-4	7:27	15:27	3.46	3.46	<17.56

FIELD NOTES:
 *STRUCTURES /PER MM² - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-3721
AIRTEKENV.COM

Date: 1/7/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No: omega HF-10
CALIBRATION DATE: 12/17/2013
EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:00 TIME OFF: 13:50
TOTAL # OF SAMPLES 11

Table with 7 columns: SAMPLE #, WORK AREA, START TIME, END TIME, INITIAL FLOW, FINAL FLOW, STRUCTURE S/PER MM^2*. Contains 11 data rows and 14 empty rows.

FIELD NOTES:

*STRUCTURES /PER MM^2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-3721
AIRTEKENV.COM

Date: 1/6/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No omega HF-10
CALIBRATION DATE: 12/17/2013
EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT: _____
TIME ON: 07:00 TIME OFF: 15:30
TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM ² *
010614-828	Inside Work Area Next to the Electrical Box Downwind B-1	7:09	15:09	3.46	3.46	<17.56
010614-829	Outside Work Area Personal Decon C-3	7:11	15:11	3.46	3.46	<17.56
010614-830	Outside Work Area Waste Decon Area Upwind C-3	7:13	15:13	3.46	3.46	<17.56
010614-831	Outside Work Area 2ft from Security Box Downwind B-1	7:15	15:16	3.46	3.46	<17.56
010614-832	Outside Work Area 4ft from Security Box Downwind B-1	7:16	15:17	3.46	3.46	<17.56
010614-833	Outside Work Area Right of Yard Downwind B-2	7:18	15:18	3.46	3.46	<17.56
010614-834	Outside Work Area Center of Yard Downwind B-2	7:20	15:20	3.46	3.46	<17.56
010614-835	Outside Work Area Left of Yard Upwind B-3	7:21	15:21	3.46	3.46	<17.56
010614-836	Outside Work Area Left of South/West Side Upwind B-4	7:23	15:23	3.46	3.46	<17.56
010614-837	Outside Work Area Center of South/West Side Upwind B-4	7:25	15:25	3.46	3.46	<17.56
010614-838	Outside Work Area Right of South/West Side Upwind A-4	7:26	15:26	3.46	3.46	<17.56

FIELD NOTES:

*STRUCTURES /PER MM² - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE

CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
 11101
 Phone (718) 937-3720 Fax (718) 937-
 3721
 AIRTEKENV.COM

Date: 1/3/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
 ADDRESS: 500 Kent Avenue
Brooklyn, NY
 ROTOMETER No omega HF-10
 CALIBRATION DATE: 12/17/2013
 EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille
 AIRTEK PROJECT #: 13-1013
 MATERIAL: Soil Excavation
 AMOUNT: _____
 TIME ON: 07:00 TIME OFF: 14:30
 TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURES /PER MM ²⁺
010314-807	Inside Work Area Next to the Electrical Box Downwind B-1	7:09	14:10	3.46	3.46	<17.56
010314-808	Outside Work Area Personal Decon C-3	7:10	14:11	3.46	3.46	<17.56
010314-809	Outside Work Area Waste Decon Area Upwind C-3	7:12	14:12	3.46	3.46	<17.56
010314-810	Outside Work Area 2ft from Security Box Downwind B-1	7:14	14:15	3.46	3.46	<17.56
010314-811	Outside Work Area 4ft from Security Box Downwind B-1	7:17	14:17	3.46	3.46	<17.56
010314-812	Outside Work Area Right of Yard Downwind B-2	7:19	14:19	3.46	3.46	<17.56
010314-813	Outside Work Area Center of Yard Downwind B-2	7:22	14:22	3.46	3.46	<17.56
010314-814	Outside Work Area Left of Yard Upwind B-3	7:24	14:24	3.46	3.46	<17.56
010314-815	Outside Work Area Left of South/West Side Upwind B-4	7:25	14:26	3.46	3.46	<17.56
010314-816	Outside Work Area Center of South/West Side Upwind B-4	7:27	14:28	3.46	3.46	<17.56
010314-817	Outside Work Area Right of South/West Side Upwind A-4	7:29	14:30	3.46	3.46	<17.56
FIELD NOTES:						
*STRUCTURES /PER MM ² - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE						
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE						



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-3721
AIRTEKENV.COM

Date: 1/2/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/17/2013
EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT: _____
TIME ON: 07:10 TIME OFF: 15:30
TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM ² *
010214-786	Inside Work Area Next to the Electrical Box Upwind B-1	7:10	15:10	3.46	3.46	<17.56
010214-787	Outside Work Area Personal Decon C-3	7:11	15:12	3.46	3.46	<17.56
010214-788	Outside Work Area Waste Decon Area Downwind C-3	7:13	15:13	3.46	3.46	<17.56
010214-789	Outside Work Area 2ft from Security Box Upwind B-1	7:15	15:15	3.46	3.46	<17.56
010214-790	Outside Work Area 4ft from Security Box Upwind B-1	7:16	15:17	3.46	3.46	<17.56
010214-791	Outside Work Area Right of Yard Upwind B-2	7:18	15:19	3.46	3.46	<17.56
010214-792	Outside Work Area Center of Yard Upwind B-2	7:20	15:20	3.46	3.46	<17.56
010214-793	Outside Work Area Left of Yard Downwind B-3	7:21	15:21	3.46	3.46	<17.56
010214-794	Outside Work Area Left of South/West Side Downwind B-4	7:23	15:23	3.46	3.46	<17.56
010214-795	Outside Work Area Center of South/West Side Downwind B-4	7:24	15:24	3.46	3.46	<17.56
010214-796	Outside Work Area Right of South/West Side Downwind A-4	7:26	15:26	3.46	3.46	<17.56

FIELD NOTES:

*STRUCTURES /PER MM² - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE