

Site Plan Requirements

- Show street names and nearby intersecting street(s)
- Show service address, which must match service address on application
- Label EV charger locations. Recommend to distinguish L2 or DCFC charging locations.
- Display approximate location and dimensions of existing and/or preferred incoming utility service or point of entry (POE), and where utility service will terminate (ie. Service-end Box, Customer Manhole, etc).
- Display north arrow
- Outline the premise
- **Recommend** to display NYC Block and Lot # or Westchester Parcel TaxID

Note: Con Edison understands that the initial site plan may not depict the final location of the service. Once the service determination ruling is completed, the final location will be determined with a Con Edison energy service representative.

